

**Regional Water Testing Laboratory**  
**Water Supply and sanitation, Amritsar**

ID No. | RWTLASR/104

Dated | 25/06/2021

**TEST REPORT**  
**Chemical Testing**


Sr. No	Group	Sample Tested in Group (√)
1.	Residues in Water	
2.	Water	

Sample Registration No. : RWTLASR/104  
Sample code given by customer : Not Applicable

Issued to: - The Principal  
Grace Public Sen. Sec. School  
Jandiala Guru, Amritsar

**SAMPLE PARTICULARS**

Ref. Letter No. : GPS/1901 /100  
Date of Receipt : 15/06/2021  
Sample code given by customer : NA  
Name / Nature of sample : Water  
Condition of the sample : Un-Sealed Sample  
Qty/Pkg : Glass Bottle  
Sampling Method : Sample not drawn by RWTLASR  
Test Start Date : 23-06-2021  
Test Completion Date : 23-06-2021

  
Quality Manager/ Sr. Chemist  
Regional Water Testing Laboratory, Amritsar

**Note:**

- ☞ The enclosed results pertain only to the sample tested.
- ☞ The report shall not be used for advertising or any legal purpose without written permission from the Head, DWSS.
- ☞ This report cannot be re-produced, except when in full, without the written permission from the Head, DWSS.
- ☞ The sample shall be destroyed after one month from the date of issue of the report.

# Regional Water Testing Laboratory, Amritsar

Date : 25/06/2021

Registration No	District	Block	Name of Place/Village	Sample Receipt Date	Date of Collection	Source	Depth	pH	TDS (mg/l)	Total Alkalinity (mg/l)	Total Hardness (mg/l)	Turbidity	Calcium (mg/l)	Magnesium (mg/l)	Chloride (mg/l)	Odour	Taste	Colour
As per IS 3025-2017 : Requirement (Acceptable limit - Permissible limit) mg/L								6.5 - 8.5	500 - 2000	200 - 600	200 - 600	1 - 5 NTU	75 - 200	30 - 100	250 - 1000			
Method Detection Limit								2.0	10.0	2.0	2.0	0.02	1.0	1.0	1.0			
RWTLASR/104	Asr	NA	Jandiala Guru	15-06-2021	15-06-2021	Not Mentioned	NA	7.02	150	128	120	0.02	32.06	35	37.98	Aggreable	Aggreable	NA

  
 Quality Manager/Sr. Chemist  
 RWTL-Amritsar

End of Report



Office Of The Municipal Council Jandiala Guru (Asr)  
Email: [mcjandiala@gmail.com](mailto:mcjandiala@gmail.com)



No... 745

Date 18/6/2021

## To Whom it May Concern

This is to Certify that we have Inspected the premises of Grace Public Sen. Sr. School Jandiala guru Amritsar (Jandiala guru- Tarn Taran Bye Pass) on 17/6/2021 After Inspecting their Class rooms and toilets we certify that their cleanliness and Sanitation is Satisfactory .

*[Signature]*  
Executive Officer,  
Municipal Council,  
Jandiala guru  
*[Signature]*

*[Signature]*  
Manager  
Grace Public Sen. Sec. School  
Jandiala Guru Amritsar  
Affiliation No 1631101  
C.B.S.E. (New Delhi)

*[Signature]*  
Principal  
Grace Public Sen. Sec. School  
Jandiala Guru Amritsar  
Affiliation No 1631191  
C.B.S.E. (New Delhi)